



Certificate number: 2402754 (1)

Issued 26/02/2024

Expires 26/02/2029

Kiwa Regulation 4 (KUKreg4) Certification

Evaluation Guideline – Kiwa UK – EG004 – Regulation 4(1)(a)

Model number(s) – see Appendix

IDC Plumbing & Heating Technology (Beijing) Ltd.

Kiwa Watertec declares that legitimate confidence exists in the products specified in this certificate and supplied by the above organisation be relied upon to comply with the Kiwa Evaluation Guideline referred above.

Which verifies the requirements of:

Regulation 4(1)a of the Water Supply (Water Fittings) Regulations 1999 England & Wales: 2009 Northern Ireland and 2014 Byelaws Scotland.

This certificate has been issued in accordance with the Kiwa regulations for product certification.

Signed on behalf of Kiwa Watertec

David Jay, Business Unit Manager – Authorised Signatory
Kiwa Watertec

Publication of this certificate is allowed.

Products are intended to be used in the UK only. For other countries, other (National) requirements will apply.

See <https://www.kiwa.com/gb/en/about-kiwa/water-products/> or the QR code below to ensure that the certificate is still valid.

Kiwa Watertec

(A Trading Division of Kiwa Ltd)
26A Rassau Industrial Estate
Ebbw Vale
Gwent
NP23 5SD
United Kingdom
T +44 (0)1495 308185
uk.water@kiwa.com
www.kiwa.co.uk

Certificate Issued to:

IDC Plumbing & Heating Technology (Beijing) Ltd
3rd Floor
Unit 2
Building 2
Section A
ZhaoWei Science & Technology Park
No. 14
Jiuxianqiao Road
Chaoyang District



KUKreg4

Product Certificate

Appendix to Certificate number: 2402754

The following products belong to this certificate

PRODUCT DESCRIPTION Range of M profile press fit single check valve assemblies with DZR brass bodies, incorporating a spring loaded resilient trim check valve with plastic body and EPDM 'o' rings. ATS3 – Without Production Surveillance.
MODEL(S) 1CVK005 1CVK007 1CVK009
SIZE: 15mm, 22mm and 28mm.
SCOPE: Manufacturer recommended maximum working pressure 10 Bar & maximum operating temperature 85°C. Hygienic Purposes: Non-metallic materials suitable for continuous use up to 85°C.
MARKING IDC, size PN, flow arrow, CR.
MATERIALS Non-metallic materials assessed (BS6920) to point of discharge.
BACKFLOW PROTECTION NOTES N/A.
ADDITIONAL NOTES All water contact & exposed components satisfy opacity requirements. No testing has been performed on the press fitting for use with compatible pipe.

Extra Notes